

A Focused Demonstration Project: The “Cozy” by Radiator Labs



Final Report | Report Number 18-12 | May 2018

NYSERDA's Promise to New Yorkers:

NYSERDA provides resources, expertise, and objective information so New Yorkers can make confident, informed energy decisions.

Mission Statement:

Advance innovative energy solutions in ways that improve New York's economy and environment.

Vision Statement:

Serve as a catalyst – advancing energy innovation, technology, and investment; transforming New York's economy; and empowering people to choose clean and efficient energy as part of their everyday lives.

A Focused Demonstration Project: The “Cozy” by Radiator Labs

Final Report

Prepared for:

New York State Energy Research and Development Authority

Albany, NY

Andrew Tighe
Project Manager

Prepared by:

Energy & Resource Solutions

George Zúñiga
Project Manager

Notice

This report was prepared by Energy & Resource Solutions in the course of performing work contracted for and sponsored by the New York State Energy Research and Development Authority (hereafter “NYSERDA”). The opinions expressed in this report do not necessarily reflect those of NYSERDA or the State of New York, and reference to any specific product, service, process, or method does not constitute an implied or expressed recommendation or endorsement of it. Further, NYSERDA, the State of New York, and the contractor make no warranties or representations, expressed or implied, as to the fitness for particular purpose or merchantability of any product, apparatus, or service, or the usefulness, completeness, or accuracy of any processes, methods, or other information contained, described, disclosed, or referred to in this report. NYSERDA, the State of New York, and the contractor make no representation that the use of any product, apparatus, process, method, or other information will not infringe privately owned rights and will assume no liability for any loss, injury, or damage resulting from, or occurring in connection with, the use of information contained, described, disclosed, or referred to in this report.

NYSERDA makes every effort to provide accurate information about copyright owners and related matters in the reports we publish. Contractors are responsible for determining and satisfying copyright or other use restrictions regarding the content of reports that they write, in compliance with NYSERDA’s policies and federal law. If you are the copyright owner and believe a NYSERDA report has not properly attributed your work to you or has used it without permission, please email print@nyserda.ny.gov

Information contained in this document, such as web page addresses, are current at the time of publication.

Abstract

Radiator Labs has developed a technology that eliminates overheating in steam-heated buildings, the predominant heating technology found in larger, older cities like NYC.

Beginning in 2013, with NYSERDA ETAC (Emerging Technologies Accelerated Commercialization) support, Radiator Labs engaged in an ETAC focused demonstration to establish the technology's impact in seven full-building deployments. After five years of third-party evaluation, the project team found that the technology saved 25% on average in all buildings evaluated with savings as high as 45%. The smallest efficiency gain (14.5%) was found in a building that, post retrofit, is among the most efficient one-pipe steam buildings in the entire NYC area, demonstrating the impact of the technology even on relatively efficient buildings.

Keywords

Steam Heat, Radiator Labs, TRV, Cozy

Table of Contents

| | |
|--|-----------|
| Notice..... | ii |
| Abstract | iii |
| Keywords..... | iii |
| List of Figures | v |
| List of Tables..... | v |
| Summary | 1 |
| 1 Site Description..... | 1 |
| 2 Measurement and Verification Data Collection..... | 2 |
| 2.1 3601 Kings Highway..... | 2 |
| 2.2 Butler Hall | 3 |
| 2.3 The Lunt-Fontanne Theatre..... | 4 |
| 2.4 1215 Myrtle Avenue | 4 |
| 2.5 295 Clinton Avenue..... | 5 |
| 3 Analysis Methodology | 6 |
| 3.1 Billing Analysis | 6 |
| 3.1.1 3601 Kings Highway | 6 |
| 3.1.2 Butler Hall..... | 8 |
| 3.1.3 1215 Myrtle Avenue..... | 10 |
| 3.1.4 The Lunt-Fontanne Theatre | 13 |
| 3.1.5 295 Clinton Avenue | 17 |
| 3.2 Boiler Run-Time Analysis | 18 |
| 3.3 Room-Temperature Analysis | 21 |
| 4 Results Summary..... | 24 |

List of Figures

| | |
|--|----|
| Figure 1. Heating Gas Use Regression–1215 Myrtle Avenue..... | 12 |
| Figure 2. District Steam Use Regression–Lunt-Fontanne Theatre..... | 16 |
| Figure 3. Boiler Run-Time Regression–3601 Kings Highway | 19 |
| Figure 4. Boiler 1 Run-Time Regression–Butler Hall | 20 |
| Figure 5. Average Room Temperature–3601 Kings Highway | 22 |
| Figure 6. Average Room Temperature–Butler Hall..... | 23 |

List of Tables

| | |
|---|----|
| Table 1. Key Site Features..... | 1 |
| Table 2. 3601 Kings Highway Metered Points..... | 2 |
| Table 3. Butler Hall Metered Points..... | 3 |
| Table 4. Lunt-Fontanne Theatre Metered Points..... | 4 |
| Table 5. 1215 Myrtle Avenue Metered Points..... | 5 |
| Table 6. 295 Clinton Avenue Metered Points | 5 |
| Table 7. 3601 Kings Highway Billing Data..... | 7 |
| Table 8. Pre-Installation Space Heating Energy Usage–3601 Kings Highway..... | 7 |
| Table 9. Post-Installation Space Heating Energy Usage–3601 Kings Highway | 7 |
| Table 10. 3601 Kings Highway Billing Analysis Summary | 8 |
| Table 11. Butler Hall Billing Data..... | 8 |
| Table 12. Pre-Installation Space Heating Energy Usage–Butler Hall..... | 9 |
| Table 13. Post-Installation Space Heating Energy Usage–Butler Hall | 9 |
| Table 14. Butler Hall Billing Analysis Summary | 9 |
| Table 15. 1215 Myrtle Avenue Billing Data..... | 10 |
| Table 16. Pre-Installation Space-Heating Energy Usage–1215 Myrtle Avenue | 11 |
| Table 17. Post-Installation Space Heating Energy Usage–1215 Myrtle Avenue..... | 11 |
| Table 18. 1215 Myrtle Avenue Billing Analysis Summary..... | 12 |
| Table 19. 1215 Myrtle Avenue Billing Analysis Summary (Linear Regression Model) | 13 |
| Table 20. The Lunt-Fontanne Theatre Billing Data..... | 13 |
| Table 21. The Lunt-Fontanne Theatre Billing Analysis Summary | 15 |
| Table 22. The Lunt-Fontanne Theatre Billing Analysis Summary | 16 |
| Table 23. 295 Clinton Avenue Billing Data | 17 |
| Table 24. Pre-Installation Space-Heating Energy Usage–295 Clinton Avenue..... | 17 |
| Table 25. Post-Installation Space-Heating Energy Usage–295 Clinton Avenue | 17 |
| Table 26. 295 Clinton Avenue Billing Analysis Summary | 18 |
| Table 27. Summary of Results | 24 |

Summary

This final project report (FPR) by Energy & Resource Solutions’ (ERS) is an Emerging Technologies and Accelerated Commercialization (ETAC) program proposal submitted by Radiator Labs, Inc. It represents a submission for a focused demonstration project as part of New York State Energy Research and Development Authority’s (NYSERDA) ETAC program under Project Opportunity Notice (PON) 2689 and performed under NYSERDA ETAC-FD-001. It involves the installation of the company’s radiator control technology in the five locations listed in Table S-1.

Table S-1. Focused Demonstration Project Locations

| Address | Building Type |
|---|---------------------------------|
| 3601 Kings Highway, Brooklyn, NY | Residential |
| 400 West 119th St. (Butler Hall), New York, NY | Dormitory (Columbia University) |
| The Lunt-Fontanne Theatre, New York, NY | Commercial |
| 295 Clinton Avenue, Brooklyn, NY | Residential |
| 1215 Myrtle Avenue, Brooklyn, NY | Residential |

Please note that information in this document is catered to specific building stock to validate a specific effort; any use of the technology outside that scope cannot be expected to produce valid results.

Radiator Labs has developed a new technology called the thermostatic radiator enclosure (TRE), also known as the “Cozy,” which aims to reduce energy consumption and improve the thermal comfort of spaces heated by steam radiators. The product consists of an insulating sleeve that fits over the existing radiator to control convective heat transfer. A small electrically powered fan in conjunction with an infrared thermostat is used to deliver heat to the room only when needed. The product is intended to reduce overheating—a common problem that faces many older buildings heated by steam radiators.

The system was previously installed in two dormitory buildings at Columbia University’s campus in New York City. As part of the Energy Performance Validation (EPV) project in the 2014–2015 season, ERS utilized three approaches for their analysis (room-temperature reduction, boiler run-time, and billing) to validate the technology at these locations and found substantial evidence of energy savings resulting

from the installations. Through the focused demonstration (FD) track of the ETAC program, the scope was expanded to additional buildings shown in Table S-1 to develop an understanding of the expected range of energy savings possible as well as the building criteria that influence the project savings.

Similar to the EPV project analysis, the ERS team constructed three approaches for their analysis, using boiler controls system trend data, Radiator Labs' network data, utility billing data, and ERS physical data loggers. Initially, a billing analysis was conducted to confirm that the installation of Cozy units at all five buildings in this study resulted in actual measurable energy savings. A boiler run-time analysis was performed for 3601 Kings Highway and Butler Hall to confirm that real quantifiable energy savings resulted in reduced run time of the space heating boilers. Finally, room-temperature analyses were performed for 3601 Kings Highway and Butler Hall to confirm that the reduced heat load reflected in ERS's boiler run-time analysis results in lower room temperatures in the post-installation scenario.

Pre-project data collection was not conducted for 295 Clinton Avenue, and post-project data collection was not conducted for 1215 Myrtle and the Lunt-Fontanne Theatre in this study; therefore, neither a room-temperature analysis nor a boiler run-time analysis was feasible for these buildings. Only the billing analysis results were utilized to calculate the energy-use savings, which are summarized in Table S-2. A billing analysis was performed using two different methodologies:

- Seasonal heating energy use per heating degree day (HDD)¹
- Linear regression analysis of monthly energy usages per HDD

The billing analysis results for the five buildings included in this study, along with the Claremont and Watt dormitories, which were part of the EPV project in the 2014–2015 season, are provided in Table S-2.

¹ HDD is a measurement designed to quantify the demand for energy needed to heat a building. It is the number of degrees that a day's average temperature is below 65°F (18°C), which is the temperature below which buildings need to be heated.

Table S-2. Results Summary

| Analysis Method | 3601 Kings Highway Savings | Butler Hall Savings | Lunt-Fontanne Savings | 1215 Myrtle Savings | 295 Clinton Avenue Savings | Claremont Hall Savings | Watt Hall Savings |
|---|-----------------------------------|----------------------------|------------------------------|----------------------------|-----------------------------------|-------------------------------|--------------------------|
| Billing reduction (seasonal analysis) ^a | 19% | 18% | 28% | 22% | 14% | 32% | 45% |
| Billing reduction (linear regression analysis) ^b | 20% | 22% | 22% | 16% | 16% | 43% | 47% |

^a The savings percentages are calculated using a seasonal 'MMBtu/HDD' consumption model and are based on the space heating energy use only. For Claremont and Watt Halls, the post-installation billing data was updated based on the most recent fuel consumption data provided, and the billing analysis results were updated from the EPV report.

^b A linear regression analysis of the monthly energy usages with historic HDD are not considered to be the preferred analysis methodology because most of the facilities in this study utilized more than one fuel type for heating in the pre- or post-installation case, which increases additional meaningless information within the data sets.

It is evident from the results shown in Table S-2 that ERS has found substantial evidence of energy savings through its analyses of the five additional buildings through the FD project. Space heating energy savings ranging from 14% to 45% were observed in the seasonal billing analysis from installation of this technology for the buildings in the EPV and FD study.

1 Site Description

Following the successful installation at two Columbia University student dormitories located in Manhattan, Radiator Labs arranged the installation of their product at five more locations in the New York Metropolitan Area. The key site features of each building are shown in Table 1.

Table 1. Key Site Features

| Building | Fuel Type | Number of Boilers | Project Installation |
|---|------------------------|--------------------------|-----------------------------|
| 3601 Kings Highway, Brooklyn | Natural gas, No. 2 oil | 1 | Jan. 2015 |
| 400 West 119th (Butler Hall), Manhattan | Natural gas, No. 4 oil | 2 | Nov. 2015–Mar. 2016 |
| The Lunt-Fontanne Theatre, Manhattan | District steam | N/A | Nov. 2015 |
| 295 Clinton Avenue, Brooklyn | Natural gas | 1 | Feb. 2016 |
| 1215 Myrtle Avenue, Brooklyn | Natural gas, No. 2 oil | 1 | Nov. 2016 |

2 Measurement and Verification Data Collection

ERS worked with Radiator Labs to collect measurement and verification (M&V) data in a few different ways. First, utility billing data was collected for all five buildings to analyze the pre- and post-installation fuel use. Boiler controls system trend data, Radiator Labs’ network data, and ERS’s physical data loggers were utilized to compile a variety of data points at 3601 Kings Highway and Butler Hall during the pre- and post-installation periods to analyze the boiler run time and room-temperature reduction. Data loggers were also installed on the boiler at 295 Clinton Avenue to analyze the post-installation boiler run time, but the loggers were not returned as planned to ERS, and hence a boiler run-time reduction analysis was not feasible. The following sections provide a list of data points collected, including the type of point, measurement method, time increment, quantity, and metering duration for each site.

2.1 3601 Kings Highway

Table 2 provides a summary of the metered points in 3601 Kings Highway.

Table 2. 3601 Kings Highway Metered Points

| Parameter/Point | Period | Discrete Points ¹ | Unit | Metering Equipment ² | Interval | Start Date | End Date |
|---|------------|------------------------------|---------|---------------------------------|-----------|------------|----------|
| Boiler aquastat | Pre- | 1 | °F | Boiler system | Daily | 10/1/14 | 4/29/15 |
| Boiler run time | Pre- | 1 | Hours | Boiler system | Daily | 10/1/14 | 4/29/15 |
| Boiler stack temp | Pre- | 1 | °F | Boiler system | Daily | 10/1/14 | 4/29/15 |
| Domestic hot water/coil temp | Pre- | 2 | °F | Boiler system | Daily | 10/1/14 | 4/29/15 |
| Domestic hot water/condensate return temp | Pre- | 2 | °F | Boiler system | Daily | 10/1/14 | 4/29/15 |
| Outdoor temp | Pre- | 2 | °F | Boiler system | Daily | 10/1/14 | 4/29/15 |
| Governing apt. temp | Pre- | 1 | °F | Boiler system | Daily | 10/1/14 | 4/29/15 |
| Boiler combustion fan current | Pre- | 1 | Amps | ERS current transformer | 2 minutes | 11/16/14 | 3/23/15 |
| Gas use | Pre-/post- | 1 | Therms | Utility meter | Monthly | 12/26/12 | 5/25/17 |
| Oil consumption | Pre-/post- | 1 | Gallons | Customer bills | Delivery | 1/24/13 | 5/30/15 |

Table 2 continued

| Parameter/Point | Period | Discrete Points ¹ | Unit | Metering Equipment ² | Interval | Start Date | End Date |
|---------------------|--------|------------------------------|-------|---------------------------------|--------------------------|------------|----------|
| Boiler blower motor | Pre- | 1 | State | ERS motor logger | State change | 11/16/14 | 5/15/15 |
| | Post- | 1 | State | ERS motor logger | State change | 1/19/16 | 5/31/16 |
| Room temp | Pre- | 7 | °F | ERS temperature logger | Approximately 10 minutes | 11/16/14 | 5/15/15 |
| | Post- | 9 | °F | ERS temperature logger | Approximately 10 minutes | 1/19/16 | 5/31/16 |

¹ Discrete points refer to the number of measurement locations; e.g., seven rooms had HOBO loggers installed to collect room temperature in the pre-project scenario, resulting in seven data sets.

² The “boiler system” metered data was collected with a system installed and operated by Entech, a boiler controls company. In addition, ERS installed a HOBO motor on/off logger on the boiler blower motor to measure run time.

2.2 Butler Hall

Table 3 provides a summary of the metered points in Butler Hall.

Table 3. Butler Hall Metered Points

| Parameter/Point | Unit | Period | Discrete Points | Metering Equipment ¹ | Interval | Start Date | End Date |
|------------------------------|---------|--------|-----------------|---------------------------------|--------------|------------|----------|
| Boiler aquastat | °F | Pre- | 1 | Boiler system | 1 minute | 11/10/14 | 5/15/14 |
| Boiler on | State | Pre- | 1 | Boiler system | State change | 12/28/14 | 6/2/15 |
| Boiler call | State | Pre- | 1 | Boiler system | State change | 12/23/14 | 5/30/15 |
| Boiler stack temp | °F | Pre- | 1 | Boiler system | 1 minute | 12/23/14 | 6/2/15 |
| Domestic hot water/coil temp | °F | Pre- | 2 | Boiler system | 15 minutes | 12/23/14 | 6/2/15 |
| Outdoor temp | °F | Pre- | 1 | Boiler system | 15 minutes | 12/23/14 | 6/2/15 |
| Governing apt. temp | °F | Pre- | 10 | Boiler system | 15 minutes | 12/23/14 | 6/2/15 |
| Oil consumption | Gallons | Pre- | 1 | Customer bills | Delivery | 4/11/14 | 3/11/15 |
| Gas use | Therms | Post- | 1 | Utility meter | Monthly | 4/8/16 | 6/7/17 |
| Boiler blower motor | State | Pre- | 1 | ERS motor logger | State change | 11/16/14 | 3/25/15 |

Table 3 continued

| Parameter/ Point | Unit | Period | Discrete Points | Metering Equipment ¹ | Interval | Start Date | End Date |
|-------------------------------|-------|--------|--------------------|------------------------------------|--------------------|------------|-------------|
| Boiler blower motor | State | Post- | 1 | ERS motor logger | State change | 1/20/16 | 5/31/16 |
| Boiler combustion fan current | Amps | Pre- | 1 | ERS current transformer | 2 minutes | 11/10/14 | 3/15/15 |
| Room temp | °F | Pre- | 8 | ERS temperature logger | Approx. 10 minutes | 11/10/14 | 5/15/15 |
| | °F | Post- | 6 | ERS temperature logger | Approx. 10 minutes | 1/20/16 | 5/17/16 |

¹ The “boiler system” metered data was collected with a system installed and operated by TriStar, a boiler controls company. In addition, ERS installed a HOBO motor on/off logger on the boiler blower motor to measure run time.

2.3 The Lunt-Fontanne Theatre

Table 4 provides a summary of the metered points in the Lunt-Fontanne Theatre. Only the facility district steam usage was collected for both pre- and post-project scenarios.

Table 4. Lunt-Fontanne Theatre Metered Points

| Parameter/ Point | Unit | Period | Discrete Points | Metering Equipment | Interval | Start Date | End Date |
|-----------------------------------|-------|----------------|--------------------|-----------------------|--------------|------------|-------------|
| Boiler call | State | Pre- | 1 | Tristar boiler system | State change | 2/16/15 | 5/14/15 |
| Outdoor temp | °F | Pre- | 1 | Tristar boiler system | 15 minutes | 2/16/15 | 5/14/15 |
| District steam use | Mlb | Pre-/ post- | 1 | Financial records | Monthly | 8/13/13 | 11/16/16 |
| Steam and condensate temperatures | °F | Pre- | 4 | ERS thermistor | State change | 11/12/14 | 2/16/15 |

2.4 1215 Myrtle Avenue

Table 5 provides a summary of the metered points at 1215 Myrtle Avenue. Only the facility natural gas usage was collected for both pre- and post-project scenarios.

Table 5. 1215 Myrtle Avenue Metered Points

| Parameter/ Point | Unit | Period | Discrete Points | Metering Equipment | Interval | Start Date | End Date |
|---------------------|--------|------------|--------------------|------------------------|--------------------------|------------|-------------|
| Boiler on | State | Pre- | 1 | Tristar boiler system | State change | 11/12/14 | 6/5/15 |
| Boiler call | State | Pre- | 1 | Tristar boiler system | State change | 11/12/14 | 6/5/15 |
| Boiler stack temp | °F | Pre- | 1 | Tristar boiler system | 1 minute | 11/12/14 | 6/5/15 |
| Outdoor temp | °F | Pre- | 1 | Tristar boiler system | 15 minutes | 11/12/14 | 6/5/15 |
| Gas use | Therms | Pre-/post- | 1 | Utility meter | Monthly | 7/14/14 | 8/17/17 |
| Room temp | °F | Pre- | 10 | ERS temperature logger | Approximately 10 minutes | 11/12/14 | 6/5/15 |

2.5 295 Clinton Avenue

Table 6 provides a summary of the metered points at 295 Clinton Avenue. Only the facility heating fuel usage was collected for both pre- and post-project scenarios.

Table 6. 295 Clinton Avenue Metered Points

| Parameter/ Point | Unit | Period | Discrete Points | Metering Equipment ¹ | Interval | Start Date | End Date |
|---------------------|---------|------------|--------------------|------------------------------------|--------------------------|------------|-------------|
| Oil consumption | Gallons | Pre-/post- | 1 | Customer bills | Delivery | 4/11/14 | 3/11/15 |
| Gas use | Therms | Pre-/post- | 1 | Utility meter | Monthly | 4/8/16 | 6/7/17 |
| Boiler blower motor | State | Post- | 1 | ERS motor logger | State change | 11/16/14 | 3/25/15 |
| Room temp | °F | Post- | 8 | ERS temperature logger | Approximately 10 minutes | 11/10/14 | 5/15/15 |

¹ The “boiler system” metered data was collected with a system installed and operated by TriStar, a boiler controls company. In addition, ERS installed a HOBO motor on/off logger on the boiler blower motor to measure run time.

3 Analysis Methodology

ERS utilized utility billing analysis methodology to calculate energy savings from the installation of Cozy units at each of the buildings. A higher degree of confidence is achieved by substantiating the results of the billing analysis methodology with boiler run-time analysis and room-temperature analysis.

- **Billing analysis.** The first approach uses utility billing data to confirm that the installation of TRE units actually led to a reduction in billed natural gas and fuel oil use in each affected building. The pre-installation and post-installation space heating fuel usage at each of the facilities per HDD data for a base temperature of 65°F are calculated and then normalized to typical meteorological year weather (TMY3) data on an annual basis to estimate the savings from the project.
- **Boiler run-time analysis.** Next, data collected about the boiler run time is used to create a regression to the outdoor weather conditions to confirm that the energy savings from the billing analysis results in reduced run time of the space heating boilers with the Radiator Labs system in place. Since pre- and post- project boiler run-time data was collected only for 3601 Kings Highway and Butler Hall, the boiler run-time analysis was completed only for these two buildings in this study.
- **Room-temperature analysis.** As a final check, the pre- and post-installation room-temperature data was used to confirm that the savings were from a drop-in temperature of the overheated rooms. Since pre- and post-project average room-temperature data was collected only for 3601 Kings Highway and Butler Hall, the room-temperature analysis was completed only for these two buildings in this study.

Due to inherent uncertainties in the methods, each had strengths and weaknesses. More emphasis was placed on the first two methods, which were expected to yield the highest confidence in savings. Each approach is discussed in greater detail in the following sections.

3.1 Billing Analysis

A billing analysis using natural gas or fuel oil deliveries during the pre- and post-installation periods was used to determine whether the installation of Cozy units at all five buildings in this study resulted in an actual decrease in energy consumption.

3.1.1 3601 Kings Highway

Data for fuel use during heating seasons from 2013 through 2017 for the 3601 Kings Highway facility was obtained through billing data. Table 9 provides the billing data for gas use and fuel oil deliveries. The facility has a dual-fired boiler, and billing data shows that both oil and natural gas were utilized by the boiler for space heating during the analysis.

Table 7. 3601 Kings Highway Billing Data

| Start | End | Fuel | Unit | Use | Equivalent MMBtu | Period |
|------------|------------|----------------|---------|--------|------------------|---------------|
| 2/25/2013 | 12/26/2014 | Natural gas | Therms | 67,032 | 6,703 | Pre- |
| 2/25/2013 | 12/26/2014 | No. 2 fuel oil | Gallons | 3,960 | 546 | Pre- |
| 12/26/2014 | 1/27/2015 | Natural gas | Therms | 6,093 | 609 | Commissioning |
| 1/27/2015 | 5/25/2017 | Natural gas | Therms | 83,992 | 8,399 | Post- |

ERS utilized the billing data from Table 7 to estimate the fuel usage for space heating in the pre- and post-installation scenarios by adjusting for domestic hot water (DHW) use as shown in Tables 8 and 9. HDDs were based on weather data from New York City’s John F. Kennedy International Airport weather station and a base temperature of 65°F.

Table 8. Pre-Installation Space Heating Energy Usage–3601 Kings Highway

| Start | End | Space Heating Use (MMBtu) | HDD |
|-----------|------------|---------------------------|-------|
| 2/25/2013 | 12/26/2014 | 5,183 | 8,223 |

Table 9. Post-Installation Space Heating Energy Usage–3601 Kings Highway

| Start | End | Space Heating Use (MMBtu) | HDD |
|-----------|-----------|---------------------------|--------|
| 1/27/2015 | 5/25/2017 | 5,809 | 11,343 |

The pre- and post-installation period energy usages for space heating were then applied to monthly TMY3 HDD (also base 65°F) to estimate the baseline, installed space heating fuel use, and annual savings. A linear regression analysis of the monthly energy usages with historic HDDs were not performed because the facility utilized more than one fuel type for heating in the pre-installation case, which increases additional meaningless information within the data sets and contributes to erroneous calculations. Table 10 provides the monthly space-heating fuel usage under TMY3 weather conditions. The billing data indicates a savings of 19% of total annual natural gas use.

Table 10. 3601 Kings Highway Billing Analysis Summary

| Month | TMY3 HDD | Post-Use (MMBtu) | Pre-Use (MMBtu) | Savings (MMBtu) |
|--------------|--------------|------------------|-----------------|-----------------|
| January | 958 | 490 | 604 | 113 |
| February | 933 | 478 | 588 | 110 |
| March | 712 | 365 | 449 | 84 |
| April | 412 | 211 | 260 | 49 |
| May | 174 | 89 | 110 | 21 |
| June | 15 | 8 | 10 | 2 |
| July | 0 | 0 | 0 | 0 |
| August | 3 | 2 | 2 | 0 |
| September | 53 | 27 | 33 | 6 |
| October | 264 | 135 | 166 | 31 |
| November | 595 | 305 | 375 | 70 |
| December | 838 | 429 | 528 | 99 |
| Total | 4,957 | 2,539 | 3,124 | 586 |

3.1.2 Butler Hall

Data for fuel use during heating seasons from 2014 through 2017 for Butler Hall was obtained through billing data. Table 11 provides billing data for gas use and fuel oil deliveries. It appears that the facility predominantly used fuel oil in the pre-installation scenario and switched over to natural gas in the post-installation scenario.

Table 11. Butler Hall Billing Data

| Start | End | Fuel | Unit | Use | Equivalent MMBtu | Period |
|-----------|-----------|----------------|---------|---------|------------------|---------------|
| 8/9/2013 | 12/9/2015 | Natural gas | Therms | 28,184 | 2,818 | Pre- |
| 8/9/2013 | 12/9/2015 | No. 2 fuel oil | Gallons | 203,529 | 29,715 | Pre- |
| 12/9/2015 | 1/8/2016 | Natural gas | Therms | 6,093 | 609 | Commissioning |
| 1/8/2016 | 6/7/2017 | Natural gas | Therms | 187,240 | 18,724 | Post- |

ERS utilized the billing data from Table 11 to estimate the space-heating fuel usage in the pre- and post-installation scenarios by adjusting for student DHW use as shown in Tables 12 and 13. The HDDs were based on weather data from New York City's Central Park weather station and a base temperature of 65°F.

Table 12. Pre-Installation Space Heating Energy Usage–Butler Hall

| Start | End | Space Heating Use (MMBtu) | HDD |
|----------|-----------|---------------------------|--------|
| 8/9/2013 | 12/9/2015 | 24,673 | 11,088 |

Table 13. Post-Installation Space Heating Energy Usage–Butler Hall

| Start | End | Space Heating Use (MMBtu) | HDD |
|----------|----------|---------------------------|-------|
| 1/8/2016 | 6/7/2017 | 6,906 | 4,007 |

The pre- and post-installation period energy usages for space heating were then applied to monthly TMY3 HDD (also base 65°F) to estimate the baseline, installed space heating fuel use, and annual savings. A linear regression analysis of the monthly energy usages with historic HDDs were not performed because the facility utilized more than one fuel type for heating in the pre-installation case, which increases additional meaningless information within the data sets and contributes to erroneous calculations. Table 14 provides the monthly space-heating fuel usage under TMY3 weather conditions. The billing data indicates a savings of 18% of the total annual natural gas use.

Table 14. Butler Hall Billing Analysis Summary

| Month | TMY3 HDD | Post-Use (MMBtu) | Pre-Use (MMBtu) | Savings (MMBtu) |
|--------------|--------------|------------------|-----------------|-----------------|
| January | 1,119 | 2,038 | 2,490 | 452 |
| February | 846 | 1,542 | 1,883 | 342 |
| March | 670 | 1,221 | 1,492 | 271 |
| April | 410 | 746 | 911 | 165 |
| May | 185 | 337 | 411 | 75 |
| June | 15 | 27 | 33 | 6 |
| July | 0 | 1 | 1 | 0 |
| August | 10 | 18 | 22 | 4 |
| September | 45 | 81 | 99 | 18 |
| October | 310 | 565 | 690 | 125 |
| November | 512 | 932 | 1,139 | 207 |
| December | 918 | 1,672 | 2,043 | 371 |
| Total | 5,040 | 9,179 | 11,215 | 2,036 |

3.1.3 1215 Myrtle Avenue

Data for natural gas use during heating seasons from 2014 through 2017 for the 1215 Myrtle Avenue facility was obtained through billing data. The facility boiler uses only natural gas as heating fuel. ERS estimated the space-heating fuel usage in the pre- and post-installation scenarios by adjusting for DHW use. The HDDs were based on weather data from New York City’s John F. Kennedy International Airport weather station and a base temperature of 65°F. Table 15 provides the billing data for gas use and space-heating gas usage in the pre- and post-installation scenarios.

Table 15. 1215 Myrtle Avenue Billing Data

| Start | End | Billed Gas Usage (Therms) | Space Heating Gas Usage (MMBtu) | HDD | Period |
|------------|------------|---------------------------|---------------------------------|-------|---------------|
| 7/14/2014 | 8/12/2014 | 51 | 0 | 0 | Pre- |
| 8/12/2014 | 9/10/2014 | 51 | 0 | 1 | Pre- |
| 9/10/2014 | 10/16/2014 | 143 | 9 | 95 | Pre- |
| 10/16/2014 | 11/10/2014 | 165 | 11 | 257 | Pre- |
| 11/10/2014 | 12/11/2014 | 686 | 63 | 697 | Pre- |
| 12/11/2014 | 1/20/2015 | 1044 | 99 | 1,148 | Pre- |
| 1/20/2015 | 2/11/2015 | 810 | 75 | 774 | Pre- |
| 2/11/2015 | 3/12/2015 | 1056 | 100 | 1,091 | Pre- |
| 3/12/2015 | 4/14/2015 | 735 | 68 | 725 | Pre- |
| 4/14/2015 | 5/18/2015 | 208 | 15 | 262 | Pre- |
| 5/18/2015 | 6/18/2015 | 99 | 4 | 80 | Pre- |
| 6/18/2015 | 7/13/2015 | 58 | 0 | 0 | Pre- |
| 7/13/2015 | 8/11/2015 | 59 | 0 | 0 | Pre- |
| 8/11/2015 | 9/11/2015 | 57 | 0 | 0 | Pre- |
| 9/11/2015 | 10/12/2015 | 61 | 1 | 80 | Pre- |
| 10/12/2015 | 11/9/2015 | 134 | 8 | 223 | Pre- |
| 11/9/2015 | 12/10/2015 | 414 | 36 | 480 | Pre- |
| 12/10/2015 | 1/19/2016 | 746 | 69 | 814 | Pre- |
| 1/19/2016 | 2/10/2016 | 610 | 56 | 631 | Commissioning |
| 2/10/2016 | 3/11/2016 | 706 | 65 | 792 | Commissioning |
| 3/11/2016 | 4/13/2016 | 487 | 43 | 582 | Post- |
| 4/13/2016 | 5/11/2016 | 209 | 15 | 326 | Post- |
| 5/11/2016 | 6/13/2016 | 90 | 3 | 98 | Post- |
| 6/13/2016 | 7/13/2016 | 56 | 0 | 4 | Post- |
| 7/13/2016 | 8/12/2016 | 45 | 0 | 0 | Post- |
| 8/12/2016 | 9/12/2016 | 45 | 0 | 0 | Post- |
| 9/12/2016 | 10/18/2016 | 144 | 9 | 126 | Post- |

Table 15 continued

| Start | End | Billed Gas Usage (Therms) | Space Heating Gas Usage (MMBtu) | HDD | Period |
|------------|------------|---------------------------|---------------------------------|-----|--------|
| 10/18/2016 | 11/9/2016 | 55 | 0 | 210 | Post- |
| 11/9/2016 | 12/12/2016 | 483 | 43 | 605 | Post- |
| 12/12/2016 | 1/11/2017 | 785 | 73 | 841 | Post- |
| 1/11/2017 | 2/15/2017 | 807 | 75 | 914 | Post- |
| 2/15/2017 | 3/13/2017 | 519 | 46 | 606 | Post- |
| 3/13/2017 | 4/11/2017 | 389 | 33 | 641 | Post- |
| 4/11/2017 | 5/12/2017 | 98 | 4 | 273 | Post- |
| 5/12/2017 | 6/13/2017 | 78 | 2 | 127 | Post- |
| 6/13/2017 | 7/19/2017 | 63 | 1 | 1 | Post- |
| 7/19/2017 | 8/11/2017 | 51 | 0 | 582 | Post- |

ERS utilized the billing data from Table 15 to estimate the space-heating fuel usage in the pre- and post-installation scenarios by adjusting for DHW use as shown in Tables 16 and 17. The HDDs were based on weather data from New York City’s John F. Kennedy International Airport weather station and a base temperature of 65°F.

Table 16. Pre-Installation Space-Heating Energy Usage–1215 Myrtle Avenue

| Start | End | Space Heating Use (MMBtu) | HDD |
|-----------|-----------|---------------------------|-------|
| 7/14/1014 | 1/19/2016 | 559 | 6,728 |

Table 17. Post-Installation Space Heating Energy Usage–1215 Myrtle Avenue

| Start | End | Space Heating Use (MMBtu) | HDD |
|-----------|-----------|---------------------------|-------|
| 3/11/2016 | 8/11/2017 | 349 | 5,354 |

The pre- and post-installation period energy uses for space heating were then applied to monthly TMY3 HDD (also base 65°F) to estimate the baseline, installed space heating fuel use, and annual savings. Table 18 provides the monthly space-heating fuel usage under TMY3 weather conditions. The billing data indicates a savings of 22% of total annual natural gas use.

Table 18. 1215 Myrtle Avenue Billing Analysis Summary

| Month | TMY3 HDD | Pre-Use (MMBtu) | Post-Use (MMBtu) | Savings (MMBtu) |
|--------------|--------------|-----------------|------------------|-----------------|
| January | 1,119 | 80 | 62 | 17 |
| February | 846 | 78 | 61 | 17 |
| March | 670 | 59 | 46 | 13 |
| April | 410 | 34 | 27 | 7 |
| May | 185 | 14 | 11 | 3 |
| June | 15 | 1 | 1 | 0 |
| July | 0 | 0 | 0 | 0 |
| August | 10 | 0 | 0 | 0 |
| September | 45 | 4 | 3 | 1 |
| October | 310 | 22 | 17 | 5 |
| November | 512 | 49 | 39 | 11 |
| December | 918 | 70 | 55 | 15 |
| Total | 5,040 | 412 | 323 | 89 |

Since the facility utilizes only natural gas for its heating needs, the pre- and post-installation period gas usage for space-heating was also regressed to HDD. The regressions are provided in Figure 1. These regressions were then applied to monthly TMY3 HDD (also base 65°F) to estimate the baseline, installed space-heating fuel use, and annual savings.

Figure 1. Heating Gas Use Regression–1215 Myrtle Avenue




Table 19 provides the monthly space-heating gas usage under TMY3 weather conditions, estimated using the linear regression models. The billing data indicates a savings of 16% of the total annual natural gas use.

Table 19. 1215 Myrtle Avenue Billing Analysis Summary (Linear Regression Model)

| Month | TMY3 HDD | Pre-Use (MMBtu) | Post-Use (MMBtu) | Savings (MMBtu) |
|--------------|--------------|-----------------|------------------|-----------------|
| January | 958 | 85 | 72 | 13 |
| February | 933 | 82 | 70 | 12 |
| March | 712 | 62 | 53 | 9 |
| April | 412 | 35 | 28 | 6 |
| May | 174 | 13 | 9 | 3 |
| June | 15 | 0 | 0 | 0 |
| July | 0 | 0 | 0 | 0 |
| August | 3 | 0 | 0 | 0 |
| September | 53 | 0 | 0 | 0 |
| October | 264 | 21 | 16 | 5 |
| November | 595 | 51 | 43 | 8 |
| December | 838 | 74 | 63 | 10 |
| Total | 4,957 | 423 | 353 | 68 |

3.1.4 The Lunt-Fontanne Theatre

Data for district steam use during heating seasons from 2014 through 2016 for the theatre was obtained through billing data. The facility uses district steam for the purposes of space heating only. The HDDs were based on weather data from New York City’s John F. Kennedy International Airport weather station and a base temperature of 65°F. Table 20 provides the billing data for gas use and space-heating gas usage in the pre- and post-installation scenarios.

Table 20. The Lunt-Fontanne Theatre Billing Data

| Start | End | Billed District Steam Usage (Mlb) | HDD | Period |
|------------|------------|-----------------------------------|------|--------|
| 8/18/2013 | 9/17/2013 | 0 | 16 | Pre- |
| 9/17/2013 | 10/16/2013 | 0 | 100 | Pre- |
| 10/16/2013 | 11/14/2013 | 24 | 373 | Pre- |
| 11/14/2013 | 12/17/2013 | 134 | 822 | Pre- |
| 12/17/2013 | 1/17/2014 | 253 | 920 | Pre- |
| 1/17/2014 | 2/18/2014 | 462 | 1193 | Pre- |
| 2/18/2014 | 3/19/2014 | 265 | 878 | Pre- |

Table 20 continued

| Start | End | Billed District Steam Usage (Mlb) | HDD | Period |
|------------|------------|-----------------------------------|-------|--------|
| 3/19/2014 | 4/17/2014 | 48 | 567 | Pre- |
| 4/17/2014 | 5/19/2014 | 0 | 302 | Pre- |
| 5/19/2014 | 6/17/2014 | 0 | 56 | Pre- |
| 6/17/2014 | 7/18/2014 | 24 | 1 | Pre- |
| 7/18/2014 | 8/18/2014 | 134 | 0 | Pre- |
| 8/18/2014 | 9/17/2014 | 253 | 11 | Pre- |
| 9/17/2014 | 10/17/2014 | 462 | 85 | Pre- |
| 10/17/2014 | 11/14/2014 | 265 | 310 | Pre- |
| 11/14/2014 | 12/17/2014 | 48 | 799 | Pre- |
| 12/17/2014 | 1/20/2015 | 0 | 994 | Pre- |
| 1/20/2015 | 2/18/2015 | 0 | 1,074 | Pre- |
| 2/18/2015 | 3/19/2015 | 0 | 956 | Pre- |
| 3/19/2015 | 4/20/2015 | 0 | 609 | Pre- |
| 4/20/2015 | 5/19/2015 | 0 | 217 | Pre- |
| 5/19/2015 | 6/28/2015 | 0 | 77 | Pre- |
| 6/28/2015 | 7/20/2015 | 14 | 0 | Pre- |
| 7/20/2015 | 8/18/2015 | 132 | 0 | Post- |
| 8/18/2015 | 9/17/2015 | 238 | 2 | Post- |
| 9/17/2015 | 10/19/2015 | 521 | 132 | Post- |
| 10/19/2015 | 11/17/2015 | 313 | 262 | Post- |
| 11/17/2015 | 12/17/2015 | 43 | 458 | Post- |
| 12/17/2015 | 1/19/2016 | 0 | 743 | Post- |
| 1/19/2016 | 2/18/2016 | 0 | 929 | Post- |
| 2/18/2016 | 3/21/2016 | 0 | 651 | Post- |
| 3/21/2016 | 4/19/2016 | 0 | 511 | Post- |
| 4/19/2016 | 5/19/2016 | 0 | 297 | Post- |
| 5/19/2016 | 6/17/2016 | 0 | 44 | Post- |
| 6/17/2016 | 7/19/2016 | 0 | 2 | Post- |
| 7/19/2016 | 8/17/2016 | 10 | 0 | Post- |
| 8/17/2016 | 9/16/2016 | 112 | 1 | Post- |
| 9/16/2016 | 10/18/2016 | 259 | 124 | Post- |
| 10/18/2016 | 11/16/2016 | 2.43 | 310 | Post- |
| 11/16/2016 | 12/19/2016 | 194 | 703 | Post- |
| 12/19/2016 | 1/19/2017 | 276 | 835 | Post- |
| 1/19/2017 | 2/16/2017 | 241 | 749 | Post- |
| 2/16/2017 | 3/21/2017 | 164 | 824 | Post- |
| 3/21/2017 | 4/18/2017 | 6 | 448 | Post- |
| 4/18/2017 | 5/17/2017 | 0 | 260 | Post- |
| 5/18/2017 | 6/16/2017 | 0 | 86 | Post- |
| 6/17/2017 | 7/18/2017 | 0 | 0 | Post- |

The pre- and post-installation period energy uses for space heating were then applied to monthly TMY3 HDD (also base 65°F) to estimate the baseline, installed space heating fuel use, and annual savings. Table 21 provides the monthly fuel usage for space-heating under TMY3 weather conditions. The billing data indicates a savings of 28% of total annual steam use.

Table 21. The Lunt-Fontanne Theatre Billing Analysis Summary

| Month | TMY3 HDD | Post-Use (MMBtu) | Pre-Use (MMBtu) | Savings (MMBtu) |
|--------------|--------------|------------------|-----------------|-----------------|
| January | 958 | 189 | 136 | 53 |
| February | 933 | 184 | 132 | 52 |
| March | 712 | 141 | 101 | 40 |
| April | 412 | 81 | 58 | 23 |
| May | 174 | 34 | 25 | 10 |
| June | 15 | 3 | 2 | 1 |
| July | 0 | 0 | 0 | 0 |
| August | 3 | 1 | 0 | 0 |
| September | 53 | 10 | 7 | 3 |
| October | 264 | 52 | 37 | 15 |
| November | 595 | 118 | 85 | 33 |
| December | 838 | 166 | 119 | 47 |
| Total | 4,957 | 980 | 704 | 277 |

Since the facility utilizes only district steam for its heating needs, the pre- and post-installation period district steam uses were also regressed to HDD. The regressions are provided in Figure 2. These regressions were then applied to monthly TMY3 HDD (also base 65°F) to estimate the baseline, installed space-heating steam use, and annual savings.

Figure 2. District Steam Use Regression–Lunt-Fontanne Theatre




Table 22 provides the district steam usage under TMY3 weather conditions, estimated using the linear regression models. The billing data indicates a savings of 22% of total annual district steam usage.

Table 22. The Lunt-Fontanne Theatre Billing Analysis Summary

| Month | TMY3 HDD | Pre-Use (Mlb) | Post-Use (Mlb) | Savings (Mlb) |
|--------------|--------------|---------------|----------------|---------------|
| January | 958 | 277 | 217 | 61 |
| February | 933 | 269 | 210 | 59 |
| March | 712 | 195 | 153 | 41 |
| April | 412 | 0 | 0 | 0 |
| May | 174 | 0 | 0 | 0 |
| June | 15 | 0 | 0 | 0 |
| July | 0 | 0 | 0 | 0 |
| August | 3 | 0 | 0 | 0 |
| September | 53 | 0 | 0 | 0 |
| October | 264 | 0 | 0 | 0 |
| November | 595 | 155 | 123 | 32 |
| December | 838 | 237 | 186 | 51 |
| Total | 4,957 | 1,133 | 888 | 245 |

3.1.5 295 Clinton Avenue

Data for fuel use during heating seasons from 2014 through 2017 for the 295 Clinton Avenue facility was obtained through billing data. Table 23 provides the billing data for gas use and fuel oil deliveries. The facility has a dual-fired boiler, and the billing data shows that both oil and natural gas were utilized by the boiler for space heating during the analysis.

Table 23. 295 Clinton Avenue Billing Data

| Start | End | Fuel | Unit | Use | Equivalent MMBtu | Period |
|------------|-----------|----------------|---------|--------|------------------|---------------|
| 10/25/2014 | 6/27/2016 | Natural gas | Therms | 88,189 | 8,819 | Pre- |
| 10/25/2014 | 6/27/2016 | No. 2 fuel oil | Gallons | 11,200 | 1,546 | Pre- |
| 6/27/2016 | 9/27/2016 | Natural gas | Therms | 5,218 | 522 | Commissioning |
| 9/27/2016 | 5/23/2017 | Natural gas | Therms | 11,149 | 1,115 | Post- |
| 9/27/2016 | 5/23/2017 | No. 2 fuel oil | Gallons | 22,100 | 3,050 | Post- |

ERS utilized the billing data from Table 23 to estimate the fuel usage for space heating in the pre- and post-installation scenarios by adjusting for DHW use, as shown in Tables 24 and 25. The HDDs were based on weather data from New York City’s John F. Kennedy International Airport weather station and a base temperature of 65°F.

Table 24. Pre-Installation Space-Heating Energy Usage—295 Clinton Avenue

| Start | End | Space Heating Use (MMBtu) | HDD |
|------------|-----------|---------------------------|-------|
| 10/25/2014 | 6/27/2016 | 6,760 | 8,999 |

Table 25. Post-Installation Space-Heating Energy Usage—295 Clinton Avenue

| Start | End | Space Heating Use (MMBtu) | HDD |
|-----------|-----------|---------------------------|-------|
| 9/27/2016 | 5/23/2017 | 2,761 | 4,262 |

The pre- and post-installation period energy uses for space heating were then applied to monthly TMY3 HDD (also base 65°F) to estimate the baseline, installed space heating fuel use, and annual savings. A linear regression analysis of the monthly energy usages with historic HDDs were not performed because the facility utilized more than one fuel type for heating in the pre-installation

case, which increases additional meaningless information within the data sets and contributes to erroneous calculations. Table 26 provides the monthly fuel usage for space heating under TMY3 weather conditions. The billing data indicates a savings of 14% of total annual natural gas use.

Table 26. 295 Clinton Avenue Billing Analysis Summary

| Month | TMY3 HDD | Pre- Use (MMBtu) | Post- Use (MMBtu) | Savings (MMBtu) |
|--------------|--------------|------------------|-------------------|-----------------|
| January | 958 | 620 | 719 | 99 |
| February | 933 | 604 | 701 | 96 |
| March | 712 | 461 | 535 | 74 |
| April | 412 | 267 | 309 | 43 |
| May | 174 | 113 | 131 | 18 |
| June | 15 | 10 | 12 | 2 |
| July | 0 | 0 | 0 | 0 |
| August | 3 | 2 | 3 | 0 |
| September | 53 | 34 | 39 | 5 |
| October | 264 | 171 | 198 | 27 |
| November | 595 | 386 | 447 | 62 |
| December | 838 | 542 | 629 | 87 |
| Total | 4,957 | 3,211 | 3,723 | 513 |


3.2 Boiler Run-Time Analysis

3601 Kings Highway. For 3601 Kings Highway, ERS installed a HOBO² motor on/off logger on the boiler combustion blower motor to measure the run time during both the pre-installation and post-installation periods, providing a continuous source of boiler firing data. The data provided an on/off signal each time the boiler switched operating modes. ERS used this data to calculate the hourly run-time percentage for the pre- and post-installation periods and regressed this hourly data against the outdoor air temperature (OAT). The pre-installation period extended from November 16, 2014, when the data was first made available through January 15, 2015, when the installation of the Radiator Labs product began. The post-installation data was collected by ERS from January 19, 2016 through May 31, 2016.

² HOBO is a trademark for an electronic device that records measurements, such as temperature or relative humidity at set intervals over time.

Figure 3 provides a regression of the hourly pre- and post-installation boiler run-time data binned by OAT. A difference in firing time percentage is evident between the pre- and post-installation periods.

Figure 3. Boiler Run-Time Regression–3601 Kings Highway



The regressions from Figure 3 were used with TMY3 to extrapolate savings to an entire heating season. The heating season was set from October 1 through May 31 as required by New York City law. Heating was modeled to be off if the OAT was above 58°F, in line with local laws and consistent with the data collected.


Nameplate data indicated that the boiler’s maximum input rate was 2.678 million British thermal units (MMBtu). ERS compared the run-time data to the utility bills for the building and estimated that, based on the observed run-time percentage, the boiler operated at an average of 50% natural gas input. The firing rate does not have an effect on the calculations in determining the savings percentage; it will only impact the magnitude (therms) of savings. For the purpose of this study—determining the validity of the product and establishing the magnitude of energy savings—the savings percentage is the critical metric to understand. Absolute savings will be contingent upon boiler size, building size, and boiler efficiency.

ERS’s boiler run-time analysis resulted in an annual energy savings of 9% and an absolute savings of approximately 2,440 therms/yr. ERS’s weather-normalized baseline energy use was 28,209 therms/yr with an as-built energy use of 25,769 therms/yr.

Butler Hall. A similar analysis was conducted for the Butler Hall dormitory building. The Butler Hall building utilizes two steam boilers with a maximum input rate of 6.4 MMBtu. The TriStar boiler system remained in place during the pre-installation period, providing a continuous source of boiler firing data from the primary boiler. The data provided an on/off signal each time the boiler switched operating modes. ERS used this data to calculate the hourly run-time percentage of the primary boiler for the pre-installation period and regressed this hourly data against the OAT. ERS installed HOB0 motor on/off loggers on the primary boiler blower motor to measure the run time during the post-installation period, providing an on/off signal each time the boiler switched operating modes. ERS used this data to calculate the hourly run-time percentage for the post-installation period and regressed this hourly data against the OAT. The pre-installation period extended from December 28, 2014, when the data was first made available through June 2, 2015, when the installation of the Radiator Labs product began. The post-installation data was collected by ERS from January 20, 2016 through May 31, 2016.

Figure 4 provides a regression of the hourly pre- and post-installation boiler run-time data binned by OAT for the primary boiler. A difference in percentage of firing time is evident between the pre- and post-installation periods.

Figure 4. Boiler 1 Run-Time Regression–Butler Hall



The regressions from Figure 4 above were used with TMY3 data to extrapolate savings to an entire heating season. The heating season was set from October 1 through May 31 as required by New York City law. Heating was modeled to be off if the OAT was above 58°F, in line with local laws and consistent with the data collected. The system was also modeled to be off after May 16 when the students moved out. The savings resulting from the run-time reduction of boiler 1 was extrapolated to boiler 2 as well, to estimate the energy savings for space heating resulting from project installation.

ERS compared the run-time data to the utility bills for the building and estimated that, based on the observed run-time percentage, the boilers operated at an average of 45% natural gas input. ERS's boiler run-time analysis resulted in an annual energy savings of 27% and an absolute savings of approximately 28,725 therms/yr. ERS's weather-normalized baseline energy use was 106,061 therms/yr with an as-built energy use of 77,336 therms/yr.


3.3 Room-Temperature Analysis

Although the boiler run time and billing analysis clearly show a decrease in energy usage, conducting a room-temperature analysis traces the energy savings back to the source. ERS's understanding is that the installation of a Cozy on each radiator is the only change that has been made to the radiator and room-temperature controls. Therefore, if the average temperature of the building is lower, it indicates that the visible drop in energy use was a result of the installed Cozy units' impact on room-temperature control.

Of the three methods of analysis, estimating the energy savings using the room-temperature data is the least certain analysis method. Energy loss from the building is highly dependent on the insulating value of the building shell (walls and roof) and infiltration rates. Both parameters are difficult to measure precisely. Adding further uncertainty to the analysis is occupancy behavior. Resident surveys conducted by Radiator Labs indicate that many residents prior to the survey opened their windows to alleviate overheating. Open windows would greatly increase the ventilation rate of the building and would impact the observed room temperatures. Therefore, given the quality of the data collected and consistent results of the billing analysis and boiler run-time analysis, the room-temperature analysis was used only to qualitatively demonstrate the reduction in space temperature control and the reduced heating load.


3601 Kings Highway. ERS installed HOBO temperature loggers in seven rooms to collect baseline and post-case data. Baseline data was collected for three months, while post-installation case data was collected for four months. The average temperature without the Cozy system was 77.0°F, while with the Cozy system installed the average room temperatures dropped to 73.0°F, a drop of 4°F. Figure 5 shows the average room temperature for the building during both the pre- and post-installation periods. Baseline temperatures ranged from 62°F to 86°F. With the Cozy system installed, temperatures consistently ranged between 66°F and 77°F, with most temperatures below 75°F.

Figure 5. Average Room Temperature—3601 Kings Highway



Butler Hall. ERS installed HOBO temperature loggers in eight rooms to collect baseline and post-case data. Baseline data was collected for five months, while post-installation case data was collected for four months. The average temperature without the Cozy system was 77.7°F, while with the Cozy system installed the average room temperatures dropped to 76.4°F, a drop of 1.3°F. Figure 6 shows the average room temperature for the building during both the pre- and post-installation periods. Baseline temperatures ranged from 68°F to 85°F. With the Cozy system installed, temperatures consistently ranged between 72°F and 82°F, with most temperatures below 77°F.

Figure 6. Average Room Temperature–Butler Hall



4 Results Summary

A summary of the analysis results is provided in Table 27.

Table 27. Summary of Results

| Method | Metric | 3601 Kings Highway | Butler Hall | Lunt-Fontanne Theatre | 1215 Myrtle Avenue | 295 Clinton Avenue | Claremont Hall* | Watt Hall* |
|-------------------|-------------------------------|--------------------|-------------|-----------------------|--------------------|--------------------|-----------------|------------|
| Billing | Reduction of total | 19% | 18% | 28% | 16% | 14% | 32% | 45% |
| | Savings (therms) | 5,856 | 20,357 | N/A | 888 | 5,127 | 5,687 | 26,203 |
| | Savings (Mlb steam) | N/A | N/A | 277 | N/A | N/A | N/A | N/A |
| Boiler run time | Run-time reduction | 9% | 27% | N/A | N/A | N/A | 28% | 41% |
| | Savings (therms) | 2,440 | 28,725 | N/A | N/A | N/A | 6,698 | 23,874 |
| | Savings (Mlb steam) | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Room temperatures | Average pre-temperature (°F) | 77.0 | 77.7 | N/A | N/A | N/A | 75.0 | 76.9 |
| | Average post-temperature (°F) | 73.0 | 76.4 | N/A | N/A | N/A | 73.2 | 73.3 |
| | Temperature reduction (°F) | 4.0 | 1.3 | N/A | N/A | N/A | 1.8 | 3.6 |
| Annual energy use | TMY3 (therms) | 31,243 | 112,150 | N/A | 4,120 | 37,234 | 23,922 | 58,230 |
| | TMY3 (Mlb steam) | N/A | N/A | 981 | N/A | N/A | N/A | N/A |

* Boiler run-time and room-temperatures analyses methodologies and results for Claremont and Watt Halls are provided in the EPV report. Additionally, for Watt and Claremont Halls, the post-installation billing data was updated based on the most recent fuel consumption data provided, and the billing analysis results were updated from the EPV report.

All seven buildings showed a reduction in the weather-normalized billed fuel use, in the range of 14% to 45% of annual fuel energy usage for space heating. Room temperatures were analyzed to confirm that 3601 Kings Highway and Butler Hall had a drop in average ambient temperature with the system installed. The average room temperature decreased between 4.0°F and 1.3°F in 3601 Kings Highway and Butler Hall, respectively. The lower air temperature resulted in a reduced heat load that was reflected in ERS's boiler run-time analysis for the buildings. Data showed that the average annual boiler run time decreased for both 3601 Kings Highway and Butler Hall, although the magnitude of the calculated savings was larger for Butler Hall, which is a university dormitory and has a correspondingly larger heating energy use.

NYSERDA, a public benefit corporation, offers objective information and analysis, innovative programs, technical expertise, and support to help New Yorkers increase energy efficiency, save money, use renewable energy, and reduce reliance on fossil fuels. NYSERDA professionals work to protect the environment and create clean-energy jobs. NYSERDA has been developing partnerships to advance innovative energy solutions in New York State since 1975.

To learn more about NYSERDA's programs and funding opportunities, visit nyserda.ny.gov or follow us on Twitter, Facebook, YouTube, or Instagram.

**New York State
Energy Research and
Development Authority**

17 Columbia Circle
Albany, NY 12203-6399

toll free: 866-NYSERDA
local: 518-862-1090
fax: 518-862-1091

info@nyserda.ny.gov
nyserda.ny.gov



NYSERDA

State of New York

Andrew M. Cuomo, Governor

New York State Energy Research and Development Authority

Richard L. Kauffman, Chair | Alicia Barton, President and CEO